



**SUPERIOR**  
SERVICES  
TANK COMPLIANCE TESTING

## MESA 2-D Tank Test

Job No: 1407 1408 1409

Customer: Cherokee Construction

Date: 7/17/2023

Location/Site Address: Cherokee Construction, 18564 Lee Highway,  
Abingdon, VA 24210

Technician: Kelly Keller

Phone:

Lic./Cert.#: M/NC242

Facility ID: 00000000

Site State: other

### Tank Testing Results Summary

Tank Number	Capacity	Contents	MESA 2-D Test Result
1	560	Regular	Pass
2	560	Diesel Offroad	Pass
3	560	Diesel	Pass

Comments:

--